




45° Elbows
SCHEDULE 80
Inches / Pounds



Nominal Pipe Size	Outside Diameter	Inside Diameter	Wall Thickness	Center to End (A)	Pipe Schedule	Approximate Weight (in Pounds)
1/2	0.840	0.546	0.147	.63	XH/80	0.13
3/4	1.030	0.722	0.154	.75	XH/80	0.17
1	1.315	0.957	0.179	.88	XH/80	0.26
1 1/4	1.660	1.278	0.191	1.00	XH/80	0.45
1 1/2	1.900	1.500	0.200	1.12	XH/80	0.66
2	2.375	1.939	0.218	1.38	XH/80	1.21
2 1/2	2.875	2.323	0.276	1.75	XH/80	2.31
3	3.500	2.900	0.300	2.00	XH/80	3.71
3 1/2	4.000	3.364	0.318	2.50	XH/80	5.3
4	4.500	3.826	0.337	3.12	XH/80	7.2
5	5.562	4.812	0.375	3.75	XH/80	13
6	6.625	5.761	0.432	5.00	XH/80	21
8	8.625	7.625	0.500	6.25	XH/80	42
10	10.750	9.562	0.594	7.50	80	78
12	12.750	11.374	0.688	8.75	80	128
14	14.000	12.500	0.750	10.00	80	179
16	16.000	14.312	0.844	11.25	80	264
18	18.000	16.124	0.938	12.50	80	371
20	20.000	17.938	1.031	13.50	80	504
24	24.000	21.562	1.219	15.00	80	858

** Dimensions conform to ASME B16.9 & material conforms to ASTM SA-234 Grade B.*